



Utility Engineering Consultants, *LLC*

Phone : 205.951.3838
FAX : 205.951.3839
WEB : www.uecllc.com

135 Gemini Circle, Suite 211
Homewood, AL 35209
P.O. Box 21918
Birmingham, Alabama 35219

March 24, 2025

City of Lafayette
50 Alabama Avenue West
Lafayette, Alabama 36862

**RE: City of Lafayette
Wastewater Treatment Plant Upgrades
CWSRF Project No. CS010403-05**

All Contractors shall acknowledge receipt of Addendum No. 1 for above referenced job by signing and returning this statement by fax to (205) 951-3839 or email to ktwymon@uecllc.com

Contractor: _____

Received by: _____

Date: _____



Utility Engineering Consultants, LLC

Phone : 205.951.3838
FAX : 205.951.3839
WEB : www.uecllc.com

135 Gemini Circle, Suite 211
Homewood, AL 35209
P.O. Box 21918
Birmingham, Alabama 35219

March 24, 2025

City of Lafayette
50 Alabama Avenue West
Lafayette, Alabama 36862

**RE: City of Lafayette
Wastewater Treatment Plant Upgrades
CWSRF Project No. CS010403-05**

ADDENDUM NO. 1

The changes, modifications and/or additions covered by and set forth in this Addendum No. 1 shall become part of and be incorporated in the Specifications, Contract Documents and Bid Documents for the above referenced project.

CLARIFICATION

- On sheet 4 the studs nor the sheet rock are required. This is the front of existing control panel
- Provide an electric gate at entrance to fence with a keypad. Use 3 #10 and 1 #10 ground in 1” conduit from control building
- The Grit system shall be designed for 1.0 MGD flow with a peak flow of 1.25 MGD
- Weir and baffles are not required to be replaced, just recaulk them at the concrete and fiberglass interface.
- Delete Section 11100, these are no longer required. The owner will furnish containers.
- Scum beach will be replaced, Heyward is now the representative for them.
- Replace aeration basin aerator shields.
- Scum pit where the new pump is to be installed requires a new top.
- All scrap mechanical to remain at plant.
- The Grit chamber shall have grating installed in inlet/outlet channels
- Slide gates are not required at the grit chamber.
- Yard hydrant to be installed next to new the grit chamber.



Utility Engineering Consultants, *LLC*

Phone : 205.951.3838
FAX : 205.951.3839
WEB : www.uecllc.com

135 Gemini Circle, Suite 211
Homewood, AL 35209
P.O. Box 21918
Birmingham, Alabama 35219

This Addendum No. 1 shall be made a part of your set of Construction Contract Documents and Specifications.
Acknowledgment of receipt of Addendum No. 1 shall be noted in the Proposal Form.

UTILITY ENGINEERING CONSULTANTS, LLC.

A handwritten signature in black ink, appearing to read 'Dave Bechtel', is written in a cursive style.

Dave Bechtel, P.E.

DB/kt

Attachment: