



Utility Engineering Consultants, *LLC*

Phone : 205.951.3838
FAX : 205.951.3839
WEB : www.uecllc.com

135 Gemini Circle, Suite 211
Homewood, AL 35209
P.O. Box 21918
Birmingham, Alabama 35219

June 6, 2025

Town of Nauvoo
176 McDaniel Avenue
Nauvoo, Alabama 35578

**RE: Town of Nauvoo
Town of Nauvoo Water Department
Water Storage Tank Rehabilitation Project
DWSRF Project No. FS010194-02**

All Contractors shall acknowledge receipt of Addendum No. 1 for above referenced job by signing and returning this statement by fax to (205) 951-3839 or email to ktwymon@uecllc.com

Contractor: _____

Received by: _____

Date: _____



Utility Engineering Consultants, LLC

Phone : 205.951.3838
FAX : 205.951.3839
WEB : www.uecllc.com

135 Gemini Circle, Suite 211
Homewood, AL 35209
P.O. Box 21918
Birmingham, Alabama 35219

June 6, 2025

Town of Nauvoo
176 McDaniel Avenue
Nauvoo, Alabama 35578

**RE: Town of Nauvoo
Town of Nauvoo Water Department
Water Storage Tank Rehabilitation Project
DWSRF Project No. FS010194-02**

ADDENDUM NO. 1

The changes, modifications and/or additions covered by and set forth in this Addendum No. 1 shall become part of and be incorporated in the Specifications, Contract Documents and Bid Documents for the above referenced project.

CLARIFICATION

Addition to Section 13202 Town of Nauvoo, Alabama Part 1- General 1.1 D.

D. Temporary Water Storage

1. Prior to taking elevated storage tank offline, Contractor shall make provisions for temporary operation storage for operation of existing water supply wells using a pneumatic tank system. Contractor shall supply portable pneumatic tank sized to ensure water distribution system pressure is maintained within the system minimum standards for the duration of the project. Contractor will connect tank to existing distribution system at location provided by City. Pneumatic tank will be sized to maintain distribution system pressure and to prevent damage to well pumps from excessive cycling. Coordinate set up of pneumatic tank with City's water system operator.

This Addendum No. 1 shall be made a part of your set of Construction Contract Documents and Specifications. Acknowledgment of receipt of Addendum No. 1 shall be noted in the Proposal Form.

UTILITY ENGINEERING CONSULTANTS, LLC.

Dave Bechtel, P.E.

DB/kt

Attachment:

WATER\WASTEWATER\GAS DESIGN OPERATOR TRAINING