



Utility Engineering Consultants, LLC

Phone : 205.951.3838
FAX : 205.951.3839
WEB : www.uecllc.com

130 Southcrest Drive, Suite 100
Homewood, AL 35209
P.O. Box 19218
Birmingham, Alabama 35219

August 9, 2021

The Sewage Disposal Board of the
City of Red Bay
P O Box 2003
Red Bay, Alabama 35582

**Re: Addendum No. 2
Sewage Disposal Board Of The City Of Red Bay
Proposed City of Red Bay Sewer Trunk Line Upgrade Project Phase 1 – Contract 4
(Material Only)
CWSRF Project No. CS010833-03
Contract No. RB20 051(A)**

All Contractors shall acknowledge receipt of Addendum No. 2 for above referenced job by signing and returning this statement by Email: jjones@uecllc.com or Fax to (205) 951-3839.

Supplier: _____

Received by: _____

Date: _____



Utility Engineering Consultants, LLC

Phone : 205.951.3838
FAX : 205.951.3839
WEB : www.uecllc.com

130 Southcrest Drive, Suite 100
Homewood, AL 35209
P.O. Box 19218
Birmingham, Alabama 35219

August 9, 2021

The Sewage Disposal Board of the
City of Red Bay
P O Box 2003
Red Bay, Alabama 35582

**Re: Addendum No. 2
Sewage Disposal Board Of The City Of Red Bay
Proposed City of Red Bay Sewer Trunk Line Upgrade Project Phase 1 – Contract 4
(Material Only)
CWSRF Project No. CS010833-03
Contract No. RB20 051(A)**

ADDENDUM NO. 2

The changes, modifications and/or additions covered by and set forth in this Addendum No. 2 shall become part of and be incorporated in the Specifications, Contract Documents and Bid Documents for the above referenced project.

CLARIFICATION

The 24" Ductile Iron Pipe shall be quoted as Class 52 pipe.

This Addendum No. 2 shall be made a part of your set of Bid Documents and Specifications. Acknowledgment of receipt of Addendum No. 2 shall be noted in on your Bid Form.

UTILITY ENGINEERING CONSULTANTS, LLC

Roderick A. Hawkins

RAH/jj