



Utility Engineering Consultants, LLC

Phone : 205.951.3838
FAX : 205.951.3839
WEB : www.uecllc.com

130 Southcrest Drive, Suite 100
Homewood, AL 35209
P.O. Box 19218
Birmingham, Alabama 35219

December 17, 2021

**City of Marion
123 E. Jefferson Street
Marion, Al 36756**

**Re: CITY OF MARION
MARION WATER TREATMENT PLANT EMERGENCY PROJECT
MA21 081**

ADDENDUM NO. 6

The changes, modifications and/or additions covered by and set forth in this Addendum No. 6 shall become part of and be incorporated in the Specifications, Contract Documents and Bid Documents for the above referenced project.

CLARIFICATIONS:

- VSI has been added to the Specification as a Supplier for the Butterfly Valve and Gate Valves.
- Fusible Disconnects shall be installed at the Flash Mixer and at each Flocculator location.
- This project is considered a tax-exempt project.

This Addendum No. 6 shall be made a part of your set of Construction Contract Documents and Specifications. Acknowledgment of receipt of Addendum No. 6 shall be noted in Section 00410 Bid Form.

UTILITY ENGINEERING CONSULTANTS, LLC

Roderick A. Hawkins

RAH/db