



Utility Engineering Consultants, LLC

Phone : 205.951.3838
FAX : 205.951.3839
WEB : www.uecllc.com

130 Southcrest Drive, Suite 100
P.O. Box 19218
Homewood, Alabama 35209

August 29, 2022

**The Town of Town Creek
P. O. Box 190
Town Creek, Al 35672**

**RE: ADDENDUM NO.1
 TOWN CREEK
 OLD HAZELWOOD DEMOLITION PROJECT
 CONTRACT NO. TC22 092**

ADDENDUM NO. 1

The changes, modifications and/or additions covered by and set forth in this Addendum No. 1 shall become part of and be incorporated in the Request for Quotes for the above referenced project.

CLARIFICATIONS

- There is no Asbestos Removal on this Project. The Asbestos was previously removed under another contract.
- There are no known Buried Tanks within the Demolition Area.
- The Contractor is responsible for Site Stabilization to prevent disturbed soils from eroding and must stay contained within the work area footprint. The land topography is rather flat.
- Material can be buried and backfilled. Materials cannot be burned on site. Any below grade concrete structures that extend beyond three (3) feet shall be broken up to a minimum of 2 feet below the existing grade and covered.

This Addendum No. 1 shall be made a part of your Proposal Quote Documents and Specifications. Acknowledgment of receipt of Addendum No. 1 shall be noted with the Proposal Form submitted.

UTILITY ENGINEERING CONSULTANTS, LLC

Roderick A. Hawkins

RAH/db

WATER/WASTEWATER/GAS DESIGN * OPERATOR TRAINING